

City of Phoenix 91st Avenue Advanced Water Purification Facility

May 1st, 2026

CENE 486C

Presented by: Clearwater Jacks Engineering (CJE)

Zephaniah Espinosa-Cordova, Cairo Linares, Amy Joy Schmitt, Karen Vera



Professionals Dedicated To Arizona's Water

Project Introduction

Purpose:

- Design an Advanced Water Purification Facility (AWPF) that can treat 30 MGD of secondary effluent from the 91st Avenue Wastewater Treatment Plant (91st Ave WWTP)
- Meet drinking water standards from Environmental Protection Agency (EPA), Arizona Department of Environmental Quality (ADEQ), and Maricopa County Environmental Services Department (MCESD)
- Design a pump station to deliver water from Tres Rios Flow Regulating Wetlands (FRW) Outfall 005 to AWPF
- Compete in the Arizona Water Student Design Competition

Clients:

- City of Pheonix
- Dr. Jeffrey Heiderscheidt
- Water Environment Federation (WEF)



Project Location




Figure 1: Location Map




Figure 2: Vicinity Map

Existing Flow Process Diagram




Figure 3: Existing Flow Process Diagram



Parcel Selection

Alternative parcel selection for location of AWPf was determined through a decision matrix

- Parcel 101-33-003 was the selected parcel with an 88-acre lot

Table 1: Simplified Parcel Selection Decision Matrix

Parcel	101-33-003	101-33-007
Accessibility (30%)	3	1
Size (30%)	2	3
Availability (20%)	3	2
Potential Hazards (20%)	3	3
Total Score	2.4	1.9




Figure 4: Project Site Map

Physical Screening Alternatives



Figure 5: Bar Screen (*FlexRake FPFS Thru-Bar Cleaning Fine Screen*)



Figure 6: Trash Rack (*Ecosol Trash Rack*)

Fine Screening Alternatives



Figure 7: Step Screen (*HUBER Fine Screen STEP SCREEN SSV*)




Figure 8: Wedge Wire Screen (*Johnson Vee-Wire Flat Panel Wedge Wire Screen*)



Figure 9: Mesh Screen (*DIG Screen and Disk Filters*)

Screening Decision Matrices

Top scoring alternatives for screening technologies for AWPf were determined through a weighted decision matrix

Table 2: Simplified Physical Screening Decision Matrix

Physical Screening	FlexRake FPFS Thru-Bar Cleaning Fine Screen	Ecosol Trashrack
Cost (15%)	2	1
Effectiveness (25%)	1	2
Durability (20%)	2	1
Maintenance (15%)	2	1
Material (10%)	2	1
Footprint (15%)	2	1
Total Score	1.75	1.25

Physical Screening

Table 3: Simplified Fine Screening Decision Matrix

Fine Screening	HUBER Fine Screen STEP SCREEN SSV	DIG Screen and Disk Filters	Johnson Vee-Wire Flat Panel Wedge Wire Screen
Cost (15%)	2	3	1
Effectiveness (25%)	2	2	3
Durability (20%)	3	1	3
Maintenance (15%)	2	1	3
Material (10%)	1	2	3
Footprint (15%)	1	2	3
Total Score	1.95	1.8	2.7

Fine Screening



Coagulation & Flocculation Alternatives




Figure 10: Chemical Structure of Aluminum Chloride




Figure 11: Chemical Structure of Aluminum Sulfate




Figure 12: Chemical Structure of Polyaluminum Chloride (PAC)

Coagulation & Flocculation Decision Matrix

Top scoring alternatives for coagulation and flocculation for AWPf were determined through a weighted decision matrix

Table 4: Coagulation and Flocculation Decision Matrix

Coagulation & Flocculation	Aluminum Sulfate	PAC	Aluminum Chloride
Cost (20%)	3	2	1
Effectiveness (30%)	2	3	1
Sludge Production (15%)	1	3	2
Dose Range (15%)	2	3	1
Toxicity (20%)	3	3	2
Total Score	2.25	2.8	1.5

Sedimentation Alternatives



Figure 13: Conventional Settling Tanks (*Ares Tank Clarifier Tank*)



Figure 14: Tube Settlers (*Brentwood Tube Settler System*)



Figure 15: Plate Settlers (*Jim Myer & Sons INC Plate Settler System*)

Sedimentation Decision Matrix

Top scoring alternatives for sedimentation for AWPf were determined through a weighted decision matrix

Table 5: Sedimentation Decision Matrix

Sedimentation	Ares Tank Clarifier Tank	Brentwood Tube Settler System	Jim Myer & Sons, INC. Plate Settler System
Cost (15%)	3	2	1
Effectiveness (25%)	1	2	3
Durability (20%)	3	1	2
Maintenance (15%)	3	1	2
Size (10%)	1	2	3
Versatility Shape (15%)	2	3	3
Total Score	1.88	1.81	2.22

Filtration Alternatives



Figure 16: Rapid Sand Filtration
(Filters ITM Sand Filters)



Figure 17: Microfiltration (*Gore MF Media Membrane*) and (*SPX Flow Membrane Filtration System*)



Figure 18: Slow Sand Filtration (*Nalco Ultrasand High Efficient Filter*)

Filtration Decision Matrix

Top scoring alternatives filtration and AF for AWPf were determined through a weighted decision matrix

Table 6: Filtration Decision Matrix

Filtration	Filters ITM Sand Filters	GORE Microfiltration Media	Nalco UltraSand High Efficient Filter
Cost (15%)	2	3	1
Effectiveness (25%)	2	2	3
Durability (20%)	3	1	3
Maintenance (15%)	2	1	3
Size (15%)	1	2	3
Footprint (10%)	1	2	3
Total Score	1.95	1.80	2.70

Advanced Treatment Alternatives



Figure 19: Nanofiltration (*DuPont Filmtec BW30 Pro-400/34 Element*)



Figure 20: Ultrafiltration (*DuPont Ultrafiltration Capabilities*)



Figure 21: Reverse Osmosis (*NF-400 Industrial Systems*)

Advanced Treatment Decision Matrix

Top scoring alternatives advanced treatment for AWPf were determined through a weighted decision matrix

Table 7: Advanced Treatment Decision Matrix

Advanced Treatment	FilmTec BW30 PRO-400/34 Element	DuPont Ultrafiltration Capabilities	NF-400 Industrial Nanofiltration Systems
Cost (15%)	1	3	2
Effectiveness (25%)	3	1	2
Durability (20%)	2	3	3
Maintenance (15%)	1	2	2
Footprint (10%)	1	3	2
Total Score	1.70	2.35	2.20

Advanced Oxidation Process Alternatives



Figure 22: Ozone and UV (MiPRO AOP)



Figure 23: Ozone and Hydrogen Peroxide
(Capital Control Ozone Generation System)




Figure 24: Hydrogen Peroxide and UV
(Advanox AOP)

AOP Decision Matrix

Top scoring alternatives AOP for AWPf were determined through a weighted decision matrix

Table 8: AOP Decision Matrix

AOP	MiPRO AOP Ozone/UV	Capital Control Ozone Generation System Ozone/Hydrogen Peroxide	ADVANOX AOP Hydrogen Peroxide/UV
Cost (15%)	2	1	3
Effectiveness (25%)	3	2	1
Dose (20%)	2	3	1
Maintenance (15%)	3	3	3
Footprint (10%)	1	3	2
Total Score	2.20	2.35	1.90

Brine Management Alternatives




Figure 25: Brine Storage Tanks (*CST Aquastore Tanks*)



Figure 26: Evaporation Ponds (*Lenntech Water Treatment*)



Figure 27: Membrane Distillation (*memsys Vacuum Multi-Effect Membrane Distillation*)

Brine Management Decision Matrix

Top scoring alternatives brine management for AWPf were determined through a weighted decision matrix

Table 9: Brine Management Decision Matrix

Brine Management	CST Aquastore Tanks	Lenntech Water Treatment Solutions Evaporation Ponds	MEMSYS Vacuum Multi Effective Membrane Distillation
Cost (20%)	2	3	1
Effectiveness (25%)	3	2	3
Durability (20%)	2	2	2
Maintenance (15%)	3	1	2
Footprint (20%)	3	1	3
Total Score	2.25	1.85	1.90

Designing Three Alternative Treatment Trains

Three treatment trains were designed to meet different goals, each created using different treatment alternatives to meet each goal

- **Treatment Train #1:** Focused on reusing the most brine while providing quality effluent water
- **Treatment Train #2:** Focused on the most cost-effective treatment processes that could still meet standards for drinking water
- **Treatment Train #3:** Focused on treatment performance and providing excellent quality drinking water

Treatment trains had core aspects for all three designs

- In-Line Coagulant Mechanical Mixer
- Flocculation Basins
- Remineralization
- Granular Activated Carbon (GAC)
- UV and Cl₂ gas



Treatment Train Alternative #1

Treatment Train #1 was design with alternatives that would reuse the most brine.




Figure 28: Treatment Train Alternative #1 Process

Treatment Train Alternative #2

Treatment Train #2 was design with alternatives that were the most cost effective.




Figure 29: Treatment Train Alternative #2 Process

Treatment Train Alternative #3

Treatment Train #3 was design with alternatives that would have the best treatment performance and water reuse.




Figure 30: Treatment Train Alternative #3 Process

Treatment Train Decision Matrix

Treatment Train alternatives were scored using criteria deemed the most important for the final treatment train design.

Table 10: Treatment Trains Decision Matrix

Treatment Train	Treatment Train #1	Treatment Train #2	Treatment Train #3
Cost (20%)	2	3	1
Operational Flexibility (25%)	2	1	3
Footprint (20%)	2	3	1
Construction Time (5%)	2	1	2
Land Usage (15%)	2	1	2
Treatment Performance (10%)	2	1	3
Total Score	2.00	1.67	2.17

Why Treatment Train #3 is the Optimal Choice

- Membrane-based train creates a compact and low land usage alternative, provides space for possible future expansions
- Reverse osmosis (RO) has highest removal rates for dissolved solids, salts, pathogens, pharmaceuticals and organics; outperforming nano and ultrafiltration
- Ensures utmost public health, trust, and transparency
- Long-term investment to the metropolitan Phoenix area for water security and resilience
- Serves as a mitigation effort for the Phoenix water scarcity problem




Figure 30: Treatment Train Alternative #3 Process

Treatment Train Design Calculation: Physical Screening

Equation 1: Headloss through Bar Screen

$$H_L = \frac{k [(v_{thru})^2 - (v_{approach})^2]}{2g}$$

Where:

H_L = Headloss, ft

k = empirical discharge coefficient

v_{thru} = velocity through the bar screen, ft/s

$v_{approach}$ = approach velocity ft/s

g = gravitational acceleration = 32.2 ft/s

Equation 2: Area

$$A = L * W$$

Where:

A = Area ft²

L = Length, ft

W = Width, ft




Figure 31 : Bar Screen Headloss vs Approach Velocity Graph

Equation 3: Approach Velocity

$$v_{approach} = \frac{Q}{A}$$

Where:

$v_{approach}$ = Approach Velocity, ft/s

Q = Flow, ft³/s

A = Area, ft²

Table 11: Bar Screening Values

Variables	Results
Flow Rate, Q	61.574 ft ³ /s
Area, A	21 ft ²
Units	6 Screens
Velocity of Approach, $V_{approach}$	0.4887 ft/s
Headloss, H	0.0083 ft

Treatment Train Design Calculation: Coagulation

Equation 4: Hydraulic Retention Time

$$t = \frac{V}{Q}$$

where

t = theoretical detention time, s

V = volume of fluid in reactor, m^3

Q = flow rate into reactor, m^3/s

Equation 5: Hydraulic Power

$$h_f = \frac{P}{\gamma Q}$$

where

h_f = Headloss, ft

γ = specific weight, $\frac{lb}{ft^3}$

P = Power, $\frac{ft \cdot lb}{s}$

Equation 6: Volume of Cylinder

$$V = \pi r^2 h$$

where

r = radius, ft

h = height, ft

Equation 7: Velocity Gradient Equation

$$G = \left(\frac{P}{\mu V} \right)^{1/2}$$

where

G = Global RMS velocity gradient, s^{-1}

P = Power of mixing input to vessel, W

μ = dynamic viscosity of water, $Pa \cdot s$

V = Volume of liquid, m^3

Table 12: Design Criteria and Given/Known Values

Design Criteria	Values	Units
Global RMS Velocity Gradient, G	3,000-5,000	s^{-1}
Detention Time	0.5	s^{-1}
Head Loss	1.0-3.0	ft
Given Values		Units
Dynamic Viscosity of Water, μ	8.9E-4	$Pa \cdot s$
Flow Rate, Q	50,000,000	gall/d
Radius of Pipe	1.75	ft
Specific Weight of Water, γ	62.4	lb/ft^3

Treatment Train Design Calculation: Coagulation Cont.

Using the equations, shown in the previous slide these results were found for the coagulation in-line mechanical mixer design.

Table 13: Coagulation Design Values

Variables	Calculated Values	Units
Volume of Pipe, V	155	ft ³
Power of mixing input to vessel, P	62,501.1	Watts
Length of Mixing in Pipe, L	16.1	ft
Head loss, H_f	10	ft

In-line mechanical mixing **In-line static mixing** **Pros:**

Design Criteria: **Design Criteria:** - no moving parts
 - G range: 3,000-5,000 s⁻¹ - Cov of 1 to 10% w/ average of 6% - no external energy source required
 - $t \approx 0.5$ s - t in range 390-1100 **Con:**
 - headloss: 0.3 to 0.9 m - Mixing time: 1-3 s - degree of mixing and mixing time function of flow rate.

Pros: Overcomes some disadvantages of static mixer - Make headloss of 0.1u-0.9 m

Velocity Gradient Equation $t = \frac{V}{Q}$

$G = \left(\frac{P}{V}\right)^{1/3}$ $t =$ theoretical detention time, s
 $G =$ global RMS velocity gradient, s⁻¹ $V =$ volume into reactor, m³
 $P =$ power of mixing input to vessel, W $Q =$ flow rate, m³/s
 $\mu =$ dynamic viscosity of water, Pa·s
 $V =$ volume of liquid, m³

40 mg/d
 $40 \times 10^3 \frac{\text{mg}}{\text{d}} \times \frac{1 \text{ gal}}{3.785 \text{ l}} \times \frac{0.0038 \text{ m}^3}{1 \text{ ft}^3} \times \frac{1 \text{ d}}{24 \text{ hrs}} \times \frac{1 \text{ hr}}{60 \text{ min}} \times \frac{1 \text{ min}}{60 \text{ s}} \times 1.75 \frac{\text{m}^3}{\text{s}}$

$G = 1.75 \text{ m}^2/\text{s}$ $Q = \left(\frac{P}{\mu G^3}\right)^{1/2}$
 $t = \frac{V}{Q}$ $t = \left(\frac{V \mu G^3}{P}\right)^{1/2}$
 $0.5 \text{ s} = \frac{V}{1.75 \text{ m}^2/\text{s}}$ $10000,000 \frac{1}{\text{s}^2} = \frac{P}{1.75^3 \text{ m}^2 \cdot \text{Pa} \cdot \text{s}}$

$(0.5 \text{ s})(1.75 \text{ m}^2/\text{s}) = V$ $(1000000 \frac{1}{\text{s}^2}) \left(7.1875 \times 10^{-4} \text{ Pa} \cdot \text{m}^3 \cdot \text{s} \right) = P$
 $V = 0.875 \text{ m}^3 = \frac{55.316 \text{ ft}^3}{1 \text{ m}^3} \times 51 \text{ ft}^3$ $12.440 \frac{\text{Pa} \cdot \text{m}^3}{\text{s}} = 12.440 \text{ W} \times \frac{1 \text{ kW}}{1000 \text{ W}} = 12.5 \text{ kW}$

42 in diameter $V = \pi r^2 h$ $h = \frac{V}{\pi r^2}$
 radius = 21 in = $\frac{21}{12}$ ft $51 \text{ ft}^3 = \pi (1.75 \text{ ft})^2 h$ $P = \text{Power (ft} \cdot \text{lb/s)}$
 radius = 1.75 ft $51 \text{ ft}^3 = 9.821 \text{ ft}^3 h$ $\gamma = 62.4 \text{ lb/ft}^3$
 $9.821 \text{ ft}^3 = 9.821 \text{ ft}^3 h$ $h = 5.2 \text{ ft}$ $Q = 62 \text{ cfs}$

$12.5 \text{ kW} = \frac{737.56 \text{ ft} \cdot \text{lb/s}}{1 \text{ kW}}$

Figure 32: Hand Calculations for the In-Line Mechanical Mixer Design



Treatment Train Design Calculation: Sedimentation Tanks Design

Equation 8: Total Surface Area

$$A_s = \frac{Q}{V_o}$$

Where:

A_s = Total Surface Area of all Plate Settlers (m²)

Q = Flow Rate (MGD, m³/day, m³/s)

V_o = Overflow Velocity (m³/d • m²)

Equation 9: Individual Tank Area

$$A_{Tank} = \frac{A_s}{n}$$

Where:

A_{Tank} = Surface Area of Tank (m²/tank)

A_s = Total Surface Area of all Plate Settlers (m²)

n = # of tanks (tanks)

Equation 10: Velocity in Settler Equation 11: Reynold's Number

$$V_{fc} = \frac{Q}{A \times \sin\theta}$$

Where:

V_{fc} = Velocity in Settler (m/s)

A = Area per tank (m²)

θ = Plate Angle (°)

$$R_e = \frac{V_{fc} \times R_H}{\nu}$$

Where:

R_e = Reynold's Number (unitless)

V_{fc} = Velocity in Settler (m/s)

R_H = Reynold's Multiplier (m)

ν = Viscosity (Pa • s)

Table 14: Assumed Sedimentation Calculations Values

Variables	Values
Flow Rate, Q	40 MGD
# of Tanks, n	6 Tanks
Plate Diameter, D _H	60 mm
Plate Angel, θ	59°
Width, W	5 m
Side Water Depth, SWD	4.90 m
Freeboard	5.50 m

Equation 12: Froude's Number

$$F_R = \frac{V_{fc}^2}{g \times R_H}$$

Where:

F_R = Froude's Number (unitless)

V_{fc} = Velocity in Settler (m/s)

g = gravity (m/s²)

R_H = Reynold's Multiplier (m)

Equation 13: Loading Rate

$$WL = \frac{Q}{n \times A_s}$$

Where:

WL = Loading Rate (m³/d • m²)

Q = Flow Rate (m³/s)

n = # of tanks

A_s = Total Surface Area of all Plate Settlers (m²)

Treatment Train Design Calculation: Sedimentation Tank Design Cont.

Using the equations, these results are found for the sedimentation tank design.

Table 15: Sedimentation Calculation Results

Variables	Results
A_s	3,312 ft ²
A_{Tank}	1,811 ft ² /tank
$L_{Settler}$	110 ft
L_{Basin}	147 ft
Total Tank Depth	18 ft
# of Tanks	6 tanks




Figure 33 : Hand Calculations for Sedimentation Design

Treatment Train Design Calculation: Sedimentation Headloss

Equation 14: Number of Orifices

$$\text{Orifices} = \frac{LW}{D_o}$$

Where:

LW = Launder Width (m)

D_o = Diameter of Orifices (m)

Equation 15: Flow Rate per Tank

$$Q_{\text{Tank}} = \frac{Q}{n}$$

Where:

Q_{Tank} = Flow Rate per Tank (m³/s)

Q = Total Flow Rate (m³/s)

n = # of Tanks

Equation 16: Flow Rate of Orifice

$$Q_{\text{Orifice}} = \frac{Q_{\text{Tank}}}{N}$$

Where:

Q_{Orifices} = Flow Rate per Orifice (m³/s)

Q_{Tank} = Flow Rate per Tank (m³/s)

N = # of Orifices

Equation 17: Area of Orifice

$$A = \frac{\pi D^2}{4}$$

Where:

A = Area per Orifice (m²)

D = Diameter of Orifice (m)

Table 16: Sedimentation Headloss Variables

Variables	Values
Flow Rate, Q	40 MGD
Number of Tanks, n	6 Tanks
Diameter of Orifices, D _{Orifices}	5 cm
Placement	1 m
Length of settler, L	34 m

Equation 18: Headloss for Orifices

$$h = \frac{1}{2g} \times \frac{Q_{\text{Orifice}}}{K \times A}$$

Where:

h = Headloss (m)

g = Gravity (m/s²)

Q_{Orifices} = Flow Rate per Orifice (m³/s)

K = Coefficient (unitless)

A = Area per Orifice (m²)

Equation 19: Minor Loss

$$\text{Minor Loss} = K \frac{v^2}{2g}$$

Where:

K = Coefficient (unitless)

v = Viscosity (Pa · s)

g = Gravity (m/s²)

Treatment Train Design Calculation: Sedimentation Headloss Cont.

Using the equations, these results are found for the sedimentation total headloss.

Table 17: Headloss for Plate Settlers

Variables	Values
Headloss, h	2.5 inch
Minor Headloss	0.8412 inch
Total Headloss	3.35 inch

Plate settler headloss calculation

$Q = 40 \text{ MGD} = 1.753 \text{ m}^3/\text{s}$
 $D_{\text{orifices}} = 80 \text{ mm}$
 $\text{Placement} = 1 \text{ m}$
 $n = 6 \text{ tanks}$
 $L = 34 \text{ m}$

estimating # of orifices per tank:

$(34 \text{ m}) (3 \text{ launders}) \left(\frac{2 \text{ sides}}{\text{launder}} \right) = 201.84 \text{ m}$
 $\frac{201.84 \text{ m}}{1 \text{ m/orifice}} = 201.84 \rightarrow \text{round up} = 202 \text{ orifices}$

flow rate determination:

$\frac{(1.753 \text{ m}^3/\text{s})}{(6 \text{ tanks})} = 0.292 \text{ m}^3/\text{s per tank}$

estimating flow rate per orifices:

$\frac{Q}{n} = \frac{(0.292 \text{ m}^3/\text{s per tank})}{(202 \text{ orifices})} = 1.45 \times 10^{-3} \text{ m}^3/\text{s orifices}$

area of orifice:

$A = \frac{\pi D^2}{4} = \frac{\pi (0.08 \text{ m})^2}{4} = 1.93 \times 10^{-3} \text{ m}^2$

headloss calculation using coeff. of 0.6:

$h = \frac{1}{2g} \left(\frac{Q/n}{k A} \right) = \frac{1}{2(9.81)} \left(\frac{(1.45 \times 10^{-3})}{(0.6)(1.93 \times 10^{-3})} \right) = 0.0036 \text{ m}$
 $\rightarrow 2.5 \text{ inches of headloss}$

minor loss:

$\text{minor loss} = k \left(\frac{v^2}{2g} \right) = 0.0717 \times 12 = 0.8412 \text{ inches}$

Total head loss = 2.5 in + 0.8412 in = 3.3412 inches

Figure 34: Headloss for Plate Settlers Hand Calculation

Proposed Flow Process Diagram




Figure 35: Final Design Proposed Flow Diagram

Final Design Water Quality

Table 18: Simplified Water Quality Table

Assumptions were used to calculate the water quality throughout treatment

Final Effluent Quality is up to standards with the:

- EPA
- ADEQ
- MCESD

Parameters	Units	Influent	Effluent
Alkalinity	mg/L as CaCO ₃	181.0	60.0
Calcium	mg/L as CaCO ₃	194.6	70.0
Chloride	mg/L	367.0	0.4
Magnesium	mg/L as CaCO ₃	131.6	30.0
pH	Unitless	7.4	7.4
Orthophosphate	mg/L as P	3.2	0.0
Potassium	mg/L	23.0	0.2
Silica	mg/L as SiO ₂	16.0	0.2
Sodium	mg/L	256.0	2.7
Sulfate	mg/L	181.0	1.9
TDS	mg/L	1142.0	0.2
Temperature	C	25.0	25.0
TKN	mg/L as N	3.3	0.0
TSS	mg/L	8.6	0.0

Sizing for AWWPF Treatment Processes

Table 19: AWWPF Preliminary Sizing

Process Equipment	Physical Sizing
Coarse Static Bar Screens	6 Units (Total Area: 126 Sq. Ft)
Mechanical Bar & Wedge-Wire Screens	10 Units (Total Area: 320 Sq. Ft)
Coagulation In-Line Mechanical Mixer	Length: 16.1 ft, Radius: 1.75 ft
Flocculation Basins	4 Basins (809 ft L x 42 ft W x 3.5 ft D)
Plate Settler Tanks	6 Tanks (130 ft L x 14 ft W)
Microfiltration Filters	Total Land Acreage: 0.5
GAC Tank	7 Filters, dimensions per filter (81 ft L x 20 ft W x 15 ft D)
RO System	Total Land Acreage: 0.5
Brine Storage Tanks	3 x 9-foot Diameter
Remineralization	Length: 16.1 ft, Radius: 1.75 ft
Ozone Contact & Medium Pressure UV	Total Area: 159 Sq. Ft
Chlorine Gas	Total Area: 159 Sq. Ft
Total Land Area	4.5 acres

Pump Alternatives

The three primary pump configurations analyzed to meet the facility's conveyance requirements.



Figure 36: Fairbanks NIJHUIS Vertical Turbine Pump



Figure 37: Submersible Pump



Figure 38: Dry Pit Centrifugal Pump

Pump Decision Matrix

The table below prioritizes the accessibility of the pump types and the structural footprint.

Table 20: Pump Decision Matrix

Pump	Vertical Turbine	Dry Pit Centrifugal	Submersible Pump
Maintenance Accessibility (60%)	3	2	1
Structural Footprint (40%)	3	1	3
Total Score	3.00	1.60	1.80

Pipe Material Alternatives

The three primary material types for the force main.



Figure 39: AWWA C905 PVC Pipe Material Example



Figure 40: Ductile Iron Pipe Material Example



Figure 41: High-Density Polyethylene Pipe Example

Pipe Sizing Alternatives

Hydraulic modeling results used to balance total dynamic head (TDH) and fluid velocity across our pipe diameter alternatives.

Table 21: Pipe Diameter Alternatives

Diameter	Q, Flow (cfs)	TDH (ft)	Velocity (ft/s):
48 Inch	23.23	64.97	1.85
	46.46	70.10	3.70
	57.91	73.57	4.58
	61.94	75.10	4.93
42 Inch	23.23	66.77	2.41
	46.46	76.60	4.83
	57.91	83.26	5.99
	61.94	86.18	6.44
36 Inch	23.23	70.98	3.29
	46.46	91.82	6.57
	57.91	105.92	8.15
	61.94	112.10	10.95

Pipe Material and Sizing Matrices

Decision matrices weighing the different criteria for the most optimal force main.

Table 22: Pipe Material Decision Matrix

Pipe Material	C905 PVC	Ductile Iron	HDPE
C Factor (20%)	3	2	3
Life Cycle Cost (40%)	3	2	2
Durability (40%)	2	2	2
Total Score	2.60	2.00	2.00

Table 23: Pipe Diameter Decision Matrix

Pipe Sizing	Diameter 36"	Diameter 42"	Diameter 48"
Velocity (40%)	2	3	1
Energy Efficiency (30%)	2	3	3
Lifecycle Cost (10%)	3	2	1
Future Capacity (20%)	1	2	3
Total Score	1.90	2.70	2.40

Proposed Site Layout





Figure 42: AWPf Proposed Detailed Site Layout

Final Hydraulic Design

- **5 Pumps (1 Standby):** 27ML-BRZ Pentair Fairbanks Nijhuis Mixed Flow Vertical Turbine
- 9920 LF Piping of AWWA C905 PVC – 42' Diameter
- **Pump Operating Point:** 86.18 ft TDH, 6944.5 GPM, 80% Efficiency with Variable Frequency Drives (VFD)
- **Design Flow Rate of 40 MGD**



Scale:
1"=8'




Figure 43: Plan View Detailed Sump Station Layout

Figure 44: Profile View Detailed Sump Station Layout

Hydraulic Final Design Calculations

Table 24: Defined Variables and Constants

Defined Variables and Units	Value
π , Pi	3.14
Minutes in a Day	1440.00
Conversion Rate for GPM to cfs	0.00223
Water Rejection Rate:	0.25
Acceleration due to Gravity (ft/s ²)	32.17
Friction Headloss (ft):	h_f
Diameter of Pipe (ft):	D
Hydraulic Radius (ft):	R_H
Velocity (ft/sec):	V
Cross-sectional Area of Flow (ft ²):	A
Flow (cfs):	Q_1

L, Pipe Length (ft):	9900.00
Hazen-Williams Constant PVC (C):	140.00
D, diameter of pipe (ft):	4.00
D, diameter of pipe (ft):	3.50
D, diameter of pipe (ft):	3.00
Minor Headloss Nominal Value (C) from FE Handbook	
10-5	0.04

Example Calculations	
<p>Equation</p> $(1)h_f = \frac{(4.73 \times L)}{(C^{1.852} \times D^{4.87}) \times Q^{1.852}}$ <p>Calculation</p> $(1)h_f = \frac{(4.73 \times 9900)}{(140^{1.852} \times 4^{4.87}) \times 61.94^{1.852}}$ <p>$h_f = 12.1$</p>	<p>Given Values:</p> <p>L (ft) = 9900.00 C = 140.00 D (ft) = 4.00 Q (cfs) = 61.94</p>
<p>Equation</p> $(2)S = \frac{h_f}{L}$ <p>Calculation</p> $(2)S = \frac{h_f}{L}$ <p>$S = 0.0012222$</p>	<p>Given Values:</p> <p>L (ft) = 9900.00 hf (ft) = 12.10</p>
<p>Equation</p> $(3)V = \frac{Q}{A}$ <p>Calculation</p> $(3)V = \frac{61.94}{(\pi \times 4^2) \div 4}$ <p>$V = 4.93$</p>	<p>Given Values:</p> <p>Q (cfs) = 61.94 A = 12.57 D (ft) = 4.00 π, Pi: 3.14</p>

Hydraulic Profile

The facility's water elevations prior to the intermediate pumps can be seen in the profile, demonstrating how the site is graded to maximize gravity flow and minimize energy inefficiencies.




Figure 45: AWPf Hydraulic Profile

Capital Cost

Table 25: AWPf Capital Cost

AWPF Capital Cost	
Hydraulic Design	\$3,354,964
Bar Screen	\$550,000
Fine Screen	\$750,000
Coagulation & Flocculation	\$250,000
Sedimentation	\$930,000
GAC	\$4,360,000
Microfiltration	\$151,100,000
Reverse Osmosis	\$201,800,000
Remineralization	\$360,000
AOP	\$4,300,000
UV & Chlorine	\$3,600,000
Brine Management	\$4,500,000
Labor	\$680,323,848
Grand Total	\$1,056,178,812

Capital cost for the AWPf in include:

- Construction
- Material
- Construction Labor

Operation & Maintenance Cost

Table 26: O&M Cost per Year for the AWPf Table

Operations & Maintenance (O&M) costs included:

- Energy
- Chemicals
- Labor for maintenance
- Replacements of materials

Category	O&M Cost per year
Energy	\$16,734,556
Chemicals	\$30,980,475
Systems	\$4,375,930
Maintenance	\$2,250,835
Labor	\$2,046,500
Total Cost	\$59,951,720

Construction Sequencing

Construction sequencing will be in 8 phases and will total around 32 months

Table 27: Construction Phasing Table

Phase	Process	Time
1	Site Preparation	Month 1-4
2	Excavation	Month 3-9
3	Structural Building	Month 5-10
4	Treatment Train Construction	Month 6-20
5	Pipe Construction	Month 10-22
6	Education Center	Month 12-24
7	Mechanical/Electrical Construction	Month 16-26
8	Testing and Full Operation	Month 26-32

Construction Sequencing Cont.




Figure 46: Outfall 005 Canal Plan

Public Outreach Plan



Figure 47: Proposed Educational Center Location

- Public Engagement and Educational meetings
- Education Center for the public
- Tour guide around FRW and 91st Ave WWTP
- Discuss and educate public on AWPf and processes/results

Conclusion

Treatment Train Design:

- Successfully created a train that can treat water to EPA, ADEQ, and MCESD drinking water standards
- Treatment train prioritizes public health, and is adaptable for Phoenix area growth
- Creates a new, safe source of drinking water for the Phoenix area
- Helps combat the water crisis within the Phoenix area

Hydraulic Design:

- Successfully designed a pump station that can deliver 40 MGD
- Pump Station houses five vertical turbine pumps with one on standby
- The pump overcomes 86.3 ft of TDH and motors are rated for 250 HP.
- 9920 LF of 42-inch Diameter AWWA C905 PVC Force Main
- Headworks of AWWPF is 40 feet above grade (Elev: 1011.1 ft) for gravity pushes the flow through the treatment train up to the intermediate pumps

Thank you!



Figure 48: CJE at the FRW



Figure 49: CJE at AZ Water Student Design Competition

Any Questions?

References

- American National Standard for Rotodynamic Pumps for Pump Intake Design. (2018). *Hydraulic Institute*.
- ARES Tech. (2025). *Clarifier technical data sheet*.
- Brentwood. (2014). *Tube settler system solution for enhanced sedimentation*.
- Burris, D. L. (n.d.). *2024 annual report*
<https://www.ocwd.com/wp-content/uploads/2024-GWRS-Annual-Report.pdf>
- CST Industries. (2023). *Aquastore glass-lined liquid storage tanks*.
<https://www.cstindustries.com/aquastore-glass-lined-steel-water-storage-tanks/>
- Davis, M. L. (2010). *Water and wastewater engineering: Design principles and practice* (2nd ed.). McGraw-Hill.
- De Nora. (2023). *Capital Controls ozone generation system: Ozone and advanced oxidation*.
- DIG Water Matters. (2024). *Screen and disc filters 3/4"-2" plastic filters with screen elements*.
- DuPont. (2026a). *FilmTec BW30 PRO-400/34 element: High rejection and low fouling brackish water RO membrane*.
- DuPont. (2026b). *DuPont ultrafiltration capabilities*.
- Environmental Protection Agency. (2014, August 15). *National pollutant discharge elimination system final regulations to establish requirements*. Federal Register.
<https://www.federalregister.gov/documents/2014/08/15/2014-12164/national-pollutant-discharge-elimination-system-final-regulations-to-establish-requirements-for>
- Filters ITM. (2020). *Sand filter FBR/FCR data sheet*.
- FlexRake FPFS. (2016). *Full-range flexibility and maximum capture with Thru-Bar cleaning: Adapts automatically to wide variations in debris*.
- Google Earth Pro. (2025). *91st Ave WWTP [Map]*.
<https://earth.google.com/web/>
- GORE. (2023). *GORE microfiltration media*.
- Gu, H., Polanco, J., Ishida, K. P., Plumlee, M. H., Boyd, M., Desormeaux, E., Juby, G. J. G., & Shad, M. F. (n.d.). *Permeate quality, advanced oxidation process treatability, and cost for two concentrate treatment technologies to enhance recovery for potable reuse*. IWA Publishing.
<https://iwaponline.com/jwrd/article/13/3/305/97481/Permeate-quality-advanced-oxidation-process>

References

- Johnson Screens. (2024a). *Industrial screens: Wedge wire screen*.
- Johnson Screens. (2024b). *Industrial screens*.
- LennTech. (2022). *Brine evaporation ponds*.
- Maricopa County. (2026). *Parcel viewer*.
<https://maps.mcassessor.maricopa.gov/>
- McCarthy Building Companies. (2011). *91st Ave UPO5 water treatment plant*.
<https://www.mccarthy.com/projects/91st-ave-upo5-water-treatment-plant>
- JMS. (2024, February 21). *Mega-settler: Plate settler for drinking water*.
<https://jmsequipment.com/mega-treatment/high-rate-clarification/mega-settler-plate-settler-drinking-water/>
- Multiquip. (2023). *Electric submersible pumps*.
- Nalco Water. (2019). *Nalco UltraSand Plus high efficiency filters (HEF)*.
- Pentair Fairbanks Nijhuis. (2024). *Vertical turbine solids handling (VTSH) pumps*.
- Pure Aqua, Inc. (2023). *Industrial nanofiltration systems NF-400 series*.
- Tchobanoglous, G., Stensel, H. D., Tsuchihashi, R., Burton, F. L., Abu-Orf, M., Bowden, G., & Pfrang, W. (2014). *Wastewater engineering: Treatment and resource recovery*. McGraw-Hill Education.
- Urban Asset Solutions. (2024). *Ecosol trash rack technical specification*.
- Van Remmen UV Technology, & Nouryon. (2020). *ADVANOX: Innovative removal of micro-pollutants for clean and safe water for everyone*.
- Vaughan, & Triton. (2025). *PSC12D: 12-inch vertical dry pit screw centrifugal pump*.
- Wedeco. (2015). *MiPro advanced oxidation process*.